



Product Service

Attestation of Conformity

No. N8A 068782 0027 Rev. 00

Holder of Certificate: **Wuhan Rixin Technology Co., Ltd.**

Building 2, PV Industrial Park,
No.6, Middle Maodianshan Road,
Wuhan Rixin Technology Co., Ltd.
Wuhan East Lake Development Zone,
430073 Wuhan, Hubei
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062113203-00

Date, 2022-01-17

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 068782 0027 Rev. 00

Model(s):

144 cells module
 DDG(P)xxx(K) (xxx=530 to 550 in step of 5)
 132 cells module
 DDR(P)xxx(K) (xxx=485 to 505 in step of 5)
 120 cells module
 DDM(P)xxx(K) (xxx=440 to 455 in step of 5)
 108 cells module
 DDP(P)xxx(K) (xxx=395 to 410 in step of 5)
 96 cells module
 DDN(P)xxx(K) (xxx=350 to 365 in step of 5)
 84 cells module
 DDN(P)xxx(K) (xxx=310 to 320 in step of 5)
 72 cells module
 DDF(P)xxx(K) (xxx=265 to 275 in step of 5)
 xxx stands for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06